

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016929
DATE: 03/17/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Foshan DTOP
CODE: 2998-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Foshan DTOP Windows and Doors Co., Ltd. No. 1 Factory Building, Fumin #3rd Road Shishan Nanhai Foshan, Guangdong, China, 528225	Series "126" Aluminum Sliding Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-2400mm(94.49") H-2100mm(82.68") Panel: W-1195mm(47.05") H-2022mm(79.61") DLO: W-1078mm(42.44") H-1908mm(75.12")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG30 2400 x 2100 (94 x 83)-FW Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: 250828097GZC-001
Expiration Date: November 30, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023