

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016702
DATE: 06/19/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Foshan YT
CODE: 2998-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Foshan YT Aluminum Co., Ltd. No. 1 Factory Building, Fumin #3rd Road Shishan Nanhai Foshan, Guangdong, China, 528225	Series "95" Aluminum Fixed Window Configuration: O Glazing: IG-Ext. 15/32" Tempered Glass/0.090 SGP Interlayer/15/32" Tempered Glass/Int. 15/32" Tempered Glass Frame: W-1500mm(59.06") H-1500mm(59.06") DLO: W-1424mm(56.06") H-1424mm(56.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG80 1500 x 1500 (59 x 59)-FW Design Pressure: ± 3840 Pa (± 80 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)

Product Tested By: Intertek, PLC
Report No: 241119110GZC-001/241119110GZC-002
Expiration Date: May 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi D".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023