

NFRC Product Certification Authorization Report



Manufacturer: Foshan DTOP Window and Doors Co., LTD. **Product Series:** Folding Door **Simulation Lab:** SFTL **Initial Cert. Date:** 03/26/2026
Street: No. 3 PanAo Factory * Shi Bei Minxi Village **Product Type:** EDSL **Sim. Report #:** MED-1225b W&D **Re-Certification Date:**
City/State/Zip: Foshan, Guangdong 528225 **Air Leakage:** **Sim. Report Date:** 07/18/2025 **Revised Date:** 01/01/1970
Print Date: 03/26/2026 **Test Date:** 01/05/2026 **Expiration Date:** 01/05/2031

CPD Number: FYT-M-3						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lys	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00001-00001	5_Double Low-E Clear- ARG -5_Clear	AT/AT	2	0.034(2)	0.709	ZE-S	Fill 1: ARG (95)	N		CL	0.47	0.25	0.46	27
	00002-00001	6_Double Low-E Clear- ARG - 6_Double Low-E Clear	AT/AT	2	0.042(2), 0.042(3)	0.472	ZE-S	Fill 1: ARG (95)	N		CL	0.46	0.25	0.40	27
	00003-00001	6_Double Low-E Clear- ARG - 6_Double Low-E Clear	AT/AT	2	0.042(2), 0.042(3)	0.591	ZE-S	Fill 1: ARG (95)	N		CL	0.47	0.25	0.40	27
	00004-00001	6_Double Low-E Clear- ARG - 6_Double Low-E Clear	AT/AT	2	0.042(2), 0.042(3)	0.709	ZE-S	Fill 1: ARG (95)	N		CL	0.47	0.25	0.40	27
	00005-00001	6_Double Low-E Clear- ARG - 6_Double Low-E Clear	AT/AT	2	0.042(2), 0.042(3)	0.787	ZE-S	Fill 1: ARG (95)	N		CL	0.47	0.25	0.40	27
	00006-00001	6_Double Low-E Clear- ARG - 6_Double Low-E Clear	AT/AT	2	0.042(2), 0.042(3)	0.866	ZE-S	Fill 1: ARG (95)	N		CL	0.47	0.25	0.40	27
	00007-00001	6_Double Low-E Clear- ARG - 6_Double Low-E Clear	AT/AT	2	0.042(2), 0.042(3)	0.945	ZE-S	Fill 1: ARG (95)	N		CL	0.47	0.25	0.40	27
	00008-00001	5_Double Low-E Clear- ARG - 5_Double Low-E Clear - ARG - 5_Clear	AT/AT	3	0.034(2), 0.034(3)	0.472,0.472	ZE-S	Fill 1: ARG (95),Fill 2: ARG (95)	N		CL	0.42	0.22	0.36	28
	00009-00001	6_Double Low-E Clear- ARG - 6_Double Low-E Clear - ARG - 6_Clear	AT/AT	3	0.042(2), 0.042(4)	0.236,0.236	ZE-S	Fill 1: ARG (95),Fill 2: ARG (95)	N		CL	0.44	0.22	0.36	27
	00010-00001	6_Double Low-E Clear- ARG - 6_Double Low-E Clear - ARG - 6_Clear	AT/AT	3	0.042(2), 0.042(4)	0.354,0.354	ZE-S	Fill 1: ARG (95),Fill 2: ARG (95)	N		CL	0.40	0.21	0.36	28

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TFTL	01/05/2026	960mm x 2090mm	0.451	0.429	MED-1225c W&D

Comments: N/A

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA
Signature:

