

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI017013  
**DATE:** 06/17/2026  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Foshan DTOP  
**CODE:** 2998-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                                                                                         | PRODUCT DESCRIPTION                                                                                                                                                                                                                                          |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Foshan DTOP Windows and Doors<br/>Co., Ltd.</b><br><br><b>No. 1 Factory Building, Fumin #3rd Road<br/>Shishan Nanhai Foshan, Guangdong,<br/>China, 528225</b> | <b>Series "120"</b><br><br><b>Aluminum Casement Window</b><br><br>Configuration: X<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-800mm(31.50") H-1500mm(59.06")<br>Vent: W-743mm(29.25") H-1500mm(59.06")<br>DLO: W-672mm(26.46") H-1372mm(54.02") |

| SPECIFICATION                                            | PRODUCT RATING                                                                                                                                                                                                 |
|----------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17<br/>CSA A440S1-19</b> | <b>Class CW-PG30 800 x 1500 (32 x 59)-C</b><br><b>Design Pressure: ±1440 Pa (±30 psf)</b><br>Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)<br>Canadian Air Infiltration/Exfiltration Level: A3 |

Product Tested By: Intertek, PLC  
Report No: 260121006GZC-003/260121006GZC-004  
Expiration Date: **February 28, 2030**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023